

Verification No.: CLGW23121453457R



## VERIFICATION OF LVD COMPLIANCE

Applicant: barpa  
Address of applicant: Rua Noé Pereira, 473, 4510-706 Fânzeres - Gondomar  
PORTUGAL  
Manufacturer: barpa  
Rua Noé Pereira, 473, 4510-706 Fânzeres - Gondomar  
PORTUGAL  
Product Description: Copper Patch Panel  
Model No.: 8223TIUCNPP, 8223YIUCNPP (T - refers to category,  
I - refers to type, U - refers to construction, C - refers to color, N -  
refers to No. of U, PP - refers to No. of Ports)  
Sufficient samples of the product have been tested and found to be in conformity with  
Test Standard: EN 50173-1:2018  
As shown in the  
Test Report Number(s): TLGW23121453457R  
Date of issue: December 22<sup>nd</sup>, 2023  
Date of expiry: December 21<sup>st</sup>, 2028

### Conclusion

This Verification of LVD Compliance has been granted to the applicant based on the results of the TCF, performed by Global Testing Services Co., Ltd. on the sample of the above-mentioned product in accordance with the provisions of the relevant specific standards and the Directive 2014/35/EU. The CE mark as shown below can be used, under the responsibility of the manufacturer, after completion of an EU Declaration of Conformity and compliance with all relevant EU Directives. The affixing of the CE marking presumes in addition that the conditions in annexes III and IV of the Directive are fulfilled.

Approved by: Hermann Weiher



For and on behalf of  
Global Testing Services Co., Ltd



Global Testing Services Co., Ltd  
E-mail: info@gts-lab.com <http://www.gts-lab.com>  
Floor 2nd, Building D-1, No. 128, Shenfu Road, Minhang District, Shanghai, China.

Copyright of this certificate is owned by Global Testing Services Co., Ltd and may not be reproduced other than in full and with the prior approval of the General Manager.